



# TOWNE ENGINEERING, INC.

PROFESSIONAL ENGINEERS • LAND SURVEYORS • EXPERT WITNESS

MAIL: P.O. BOX 162 SOUTH WINDHAM, CT 06266

OFFICE: 1 RICHMOND LANE, WILLIMANTIC, CT 06226

(860) 423-6371 • (860) 889-2100 • Fax (860) 423-5470

DONALD R. AUBREY, P.E., L.S.  
JOSEPH H. BOUCHER, M.S., L.S.

December 30, 2025

Planning and Zoning Commission  
Att: John Guszkowski, Zoning Enforcement Officer  
Town of Sterling  
P.O. Box 157,  
Oneida, CT 06373-0157

Re: Erosion & Sedimentation Inspection Report  
Strmiska Excavation, 140 Newport Rd, Sterling, CT  
TEI Job #23-111

Dear Commissioners,

I conducted an Erosion & Sedimentation (E&S) site inspection on Wednesday December 24, 2025 with John Guszkowski, Zoning Enforcement Officer.

At the time of inspection, the gate was open and we met Jeffrey Strmiska, site operator and owner on site. The access road leading into the site is in good condition. The stone check dams, silt traps, and cross culvert all seem to be maintained and are functioning as they should be. Lots of material has been moved since my last inspection, you can now drive between the westerly side of the site to the lower area on the east side of the site.

It was discovered that the center portion of the site in phase one consists of ledge and is being left alone for now. The vegetated buffer on the east side of the site remains in good condition, along with the sedimentation basin and overflow structure located in the lower active area.

Overall, the site is fully contained, and is being maintained well. If you have any questions, comments or need any additional information please contact me at my office, Mon.-Fri., 8am to 5pm at 860-423-6371 or via email any time at [mmaynard@townengineeringinc.com](mailto:mmaynard@townengineeringinc.com).

Sincerely,

Matthew D. Maynard, P.E.  
Owner, Towne Engineering, Inc.  
Consulting Town Engineer for the Town of Sterling

cc: J. Joslyn, First Selectman